

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0811:0133 Page 1 of 1

CATEGORY: 7300 -- MISC. DEVICE/CONTROL UNIT ACCESSORIES

LISTEE: Federal Signal, 2645 Federal Signal Drive, University Park, IL 60466-3195
Contact: Sean Moloney (708) 587-3324 Fax (708) 534-4878
Email: smoloney@federalsignal.com

DESIGN: Model 224XST general signaling (non-fire alarm) strobe light for use in hazardous locations, Class I, Div. 2, group A, B, C and D; Class II, Div. 2, Group F and G; and Class III. Refer to listee's data sheet for additional product description and operational considerations.

RATING: 120/240 VAC, 12/24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as general signaling (non fire alarm) strobe lights for use with separately listed compatible fire alarm control units. Not suitable for the hearing impaired application. Intended for indoor or outdoor use. Enclosure is rated NEMA or Type 4x and IP66.

NOTE:

*Rev. 06-18-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **July 01, 2010**

Listing Expires **June 30, 2011**

Authorized By: **FRANCIS MATEO**, Program Coordinator
Fire Engineering Division