

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7300-0811:0135 Page 1 of 1

**CATEGORY:** 7300 -- MISC. DEVICE/CONTROL UNIT ACCESSORIES

**LISTEE:** Federal Signal, 2645 Federal Signal Drive, University Park, IL 60466-3195  
Contact: Sean Moloney (708) 587-3324 Fax (708) 534-4878  
Email: smoloney@federalsignal.com

**DESIGN:** Model FB24ST general signaling (non-fire alarm) strobe light. Refer to listee's data sheet for additional product description and operational considerations.

**RATING:** Electrical: 120/240 VAC, 12/24 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as non-fire alarm strobe lights for use with separately listed compatible fire alarm control units. Intended for indoor and outdoor use. Enclosure is rated NEMA or Type 4x. Not suitable for the hearing impaired application.

**NOTE:**

\*Rev. 06-18-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **July 01, 2010**

Listing Expires **June 30, 2011**

Authorized By: **FRANCIS MATEO**, Program Coordinator  
Fire Engineering Division