



Certificate of Compliance

Certificate: 1126286

Master Contract: 165016

Project: 1863033

Date Issued: 2006/12/21

Issued to: Federal Signal Corporation
2645 Federal Signal Dr
University Park, IL 60466-3195
USA
Attention: Leonard Steinbeigle

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Issued by: Jerry Tang-Kong, C.E.T.

Authorized by: Calvin McKenzie, Product Group Manager

PRODUCTS

CLASS 4812 05 - SIGNAL APPLIANCES - Systems

Visual Signaling Appliance, Models LP3 and LP6 strobe, rated 120V ac, 50/60Hz, 0.10A, 230-240V ac, 50/60Hz, 0.07A and 12-48V dc, 0.44-0.10A, for indoor/outdoor use, Type 4X enclosure.

Visual Signal Appliance, Model LP3 Incandescent, rated 12V dc, 1.04A; 24V dc, 0.67A; 120V ac, 50/60Hz, 0.13A.

Visual Signal Appliance, Model LP3 LED, rated 24V ac/dc, 50/60Hz, 0.080A; 120V ac, 50/60Hz, 0.045A.

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.



Certificate: 1126286

Master Contract: 165016

Project: 1863033

Date Issued: 2006/12/21

Note: The Model LP3 may have a suffix to denote the mounting base method and Lead Wire Configuration.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No 205-M1983 - Signal Equipment

CAN/CSA-C22.2 No 94-M91 - Special Purpose Enclosures

UL Std No 1638 - Visual Signalling Appliances