



**Underwriters  
Laboratories Inc.®**

**Northbrook Division**  
333 Pfingsten Road  
Northbrook, IL 60062-2096 USA  
www.ul.com  
tel: 1 847 272 8800  
fax: 1 847 272 8129  
Customer service: 1 877 854 3577

FEDERAL SIGNAL CORP SIGNAL DIV  
MR. LEONARD STEINBEIGLE  
2645 FEDERAL SIGNAL DR  
UNIVERSITY PARK IL 60466

**RE: Project Number(s) - 08NB**

Your most recent Certification is shown below. Please review the text and contact the Customer Service Professional who assisted with your project if revisions are required.

To view your company's current Listing Information or for ordering Listing Information in the 3 x 5-inch card format, please refer to [www.ul.com](http://www.ul.com).

UJPX7 February 7, 2008  
Signal Appliances, Miscellaneous for Use in Hazardous Locations Certified for Canada

**FEDERAL SIGNAL CORP SIGNAL DIV**  
**2645 FEDERAL SIGNAL DR, UNIVERSITY PARK IL 60466**

**E84580**

Class I, Groups C and D; Class II, Groups E, F and G; Class III. Class I, Groups A and B, Division 2.  
Beacon lights, Model\* 121X, Series C or C1, Type 4X, for indoor or outdoor use.  
Strobe light, Model\* FB2PXTX, Series A, for indoor or outdoor use, IP66 and Type 4X enclosure.  
Class I, Groups A, B, C and D, Division 2; Class II, Groups F and G, Division 2; Class III.  
Intercom, Models\*\* 310X-MV, AD-28X-MV, Type 4X, for indoor or outdoor use.  
Single message commcenter, Model\*\*\* 300SMX, Type 4X.  
Class I Division 2; Class II Groups E and F; Class III.  
Visual signal device, threaded for rigid conduit connections.  
Model 191X, 120 or 250 V ac, 40 W max, Type 4X enclosure. Insulation for supply connections should be suitable for 85 C.  
Class I, Division 2.  
Model 191X, 120 or 250 v ac, 100 W max, Types 4X, IP66 enclosure. Insulation for supply connections should be suitable for 125 C.  
Class I, Division; Class II, Groups E and F.  
Model 191X, 120 or 250 v ac, 40 W max, Type 4X enclosure. Insulation for supply connections should be suitable for 85 C.  
Class I, Division 2; Class II Groups E, F and G; Class III.  
Model 191XF, 120 v ac, 20 W max, Type 4X enclosure. Insulation for supply connections should be suitable for 75 C. Model 191XL, 24 v dc or 120 v ac, Types 4X, IP66 enclosure. Insulation for supply connections should be suitable for 60 C.  
\*Also Listed as a Marine Visual Signal Device, UXUB.  
\*\*Also Listed as a Marine Signal Appliance, UXPL.  
\*\*\*Also listed as Industrial Control Equipment, Miscellaneous Apparatus NMTR.

**LOOK FOR LISTING MARK ON PRODUCT**

An independent organization working for a safer world with integrity, precision and knowledge.

148431003



**Distributed by Gross Automation | +1 (262) 252-1600 | [sales@grossautomation.com](mailto:sales@grossautomation.com)**